

The connecting wiring between the outdoor and indoor units should be 14-4 (14 gauge 4 conductor) SOOW cable. It is recommended that the wire connections be made with spade terminals. If spade terminals are not used then the wires should not be twisted prior to connecting to the screw terminals. All strands of the wires need to be tightened to the terminal with no fraying. The cable should be secured with the strain relief clamp.

